

NYSEG QUALIFYING UPGRADE DISCLOSURE					
Substation	Upgrade	Planning Grade Estimate	Incremental Hosting Capacity (MW)	Percentage Received	Milestone Schedule*
Afton	Substation Transformer	\$4,214,044*	17.25	25%	
Afton	Substation Transformer	\$13,635,548	6.30	0%	
Amawalk	3V0 Installation	\$756,641	27.90	25%	18 months
Apalachin Tap	3V0 Installation	\$455,244	22.50	25%	18 months
Arkville	3V0 Installation	\$658,051	6.60	75%	18 months
Atlanta	Substation Regulator	\$376,410	18.30	27%	3-5 years
Axtell Rd	3V0 Installation	\$617,654	27.22	37%	18 months
Bailey Hill Tap	Distribution Line Upgrade	\$356,234	9.80	100%	18 months
Bainbridge	3V0 Installation	\$585,938	10.50	0%	
Bainbridge	Distribution Line Upgrade	\$1,789,107	9.80	0%	
Bainbridge	Substation Transformer	\$10,456,018	28.00	0%	
Banker Road	3V0 Installation	\$672,191	16.80	48%	18 months
Banker Road	3V0 Installation	\$853,070	5.20	0%	
Banker Road	Distribution Line Upgrade	\$2,011,784	9.80	0%	
Banker Road	Substation Regulator	\$1,731,212	3.70	0%	
Banker Road	Substation Transformer	\$10,427,022	28.00	0%	
Bankert Rd	3V0 Installation	\$582,866	5.21	81%	18 months
Bankert Rd	Distribution Line Upgrade	\$621,000	3.16	81%	18 months
Bennett	Distribution Line Upgrade	\$621,000	9.80	100%	18 months
Bennett	Distribution Line Upgrade	\$385,000	26.27	0%	
Bennett	Substation Regulator	\$428,508	5.67	72%	18 months
Bennington	3V0 Installation	\$692,192	2.06	0%	
Berkshire	Substation Transformer w/3v0	\$9,228,656	7.30	0%	
Berkshire	Distribution Line Upgrade	\$521,640	3.00	0%	
Brooktondale Tap	Distribution Line Upgrade	\$1,676,700	25.89	100%	18 months
Brooktondale Tap	Substation Regulator	\$1,490,162	15.16	94%	18 months
Bulkhead	Distribution Line Upgrade	\$1,419,606	9.80	0%	
Bulkhead	Substation Transformer w/3v0	\$12,100,954	10.50	0%	
Candor	Distribution Line Upgrade	\$762,490	26.50	0%	
Cayuga	3V0 Installation	\$865,537	3.60	0%	
Cayuga	Substation Regulator	\$2,087,165	2.10	0%	
Center Village	3V0 Installation	\$865,537	2.60	0%	
Chemung	Distribution Line Upgrade	\$627,210	9.80	0%	
Chemung	Substation Transformer	\$20,356,830	20.10	0%	
Chenango Bridge	Substation Regulator	\$1,620,638	3.60	0%	
Chestnut Ridge	3V0 Installation	\$448,646	10.50	48%	18 months
Chestnut Ridge	Distribution Line Upgrade	\$496,800	10.50	100%	18 months
Cobble Hill	Distribution Line Upgrade	\$596,160	9.09	0%	
Columbus	3V0 Installation	\$468,239	16.80	58%	18 months
Conklin	3V0 Installation	\$865,537	3.60	0%	
Conklin	Source Regulator	\$1,620,638	2.10	0%	
Dannemora	3V0 Installation	\$702,474	5.70	0%	
Dannemora	Substation Transformer	\$3,625,220*	5.70	0%	
Delhi	Distribution Line Upgrade	\$310,027	9.80	100%	18 months
Dover Plains	3V0 Installation	\$514,074	6.30	56%	18 months
Dryden Tap	Distribution Line Upgrade	\$741,101	1.49	0%	
Earlville	3V0 Installation ³	\$651,184	10.50	38%	18 months
Earlville	Distribution Line Upgrade	\$4,220,563	9.80	0%	
Earlville	Substation Transformer	\$10,790,216	10.50	0%	
Emmons	3V0 Installation	\$661,558	3.64	27%	18 months
Fallbrook	3V0 Installation	\$627,702	7.00	0%	
Fallbrook	Distribution Line Upgrade	\$4,692,285	9.80	0%	
Flat Street	Distribution Line Upgrade	\$3,105,000	8.70	0%	18 months
Flat Street	Distribution Line Upgrade	\$2,500,000	8.70	0%	
Fosterdale	Substation Regulator	\$434,244	1.45	25%	18 months
Frog Valley	Distribution Line Upgrade	\$3,715,038	9.80	0%	
Frog Valley	Substation Transformer	\$12,754,386	10.50	0%	
Fuller Hollow	3V0 Installation	\$436,141	16.80	28%	
Fuller Hollow	Distribution Line Upgrade	\$474,506	5.90	0%	
Gainesville	Distribution Line Upgrade	\$1,111,838	27.11	0%	
Genegantslet Corners	Substation Regulator	\$1,620,638	15.10	0%	
Halsey Valley	Distribution Line Upgrade	\$4,534,613	15.20	0%	0
Hammond Lane	3V0 Installation	\$428,401	11.65	30%	18 months
Hammond Lane	3V0 Installation	\$865,537	8.10	0%	
Hammond Lane	Distribution Line Upgrade	\$2,878,965	9.80	0%	
Hampton Road	3V0 Installation	\$865,537	3.70	0%	
Hampton Road	Distribution Line Upgrade	\$457,677	1.40	0%	
Harford	Distribution Line Upgrade	\$2,412,585	TBD	0%	
Hickling	Substation Regulator	\$1,282,649	7.50	58%	18 months
Hillcrest Rd.	3V0 Installation	\$565,091	6.60	0%	
Hoadley Hill Tap	Distribution Line Upgrade	\$794,880	6.20	0%	
Hyatt Rd	Distribution Line Upgrade	\$496,800	9.80	100%	18 months
Hyde	3V0 Installation	\$865,537	4.10	0%	
Interlaken	3V0 Installation	\$709,309	16.80	0%	
Interlaken	Distribution Line Upgrade	\$1,599,292	9.80	0%	
Interlaken	Substation Transformer	\$4,317,808*	10.50	0%	
Kattelville	3V0 Installation	\$861,293	28.80	44%	18 months
Keuka-Elmira	3V0 Installation	\$705,241	3.51	0%	
Kiamesha	Distribution Line Upgrade	\$3,023,813	9.80	0%	
Lakeshore	Distribution Line Upgrade	\$1,925,100	4.90	0%	
Langdon	Distribution Line Upgrade	\$384,009	3.68	100%	18 months
Langdon	Distribution Line Upgrade	\$807,300	27.10	0%	
Langdon	3V0 Installation	\$865,537	6.10	0%	
Legion Drive	Substation Regulator	\$595,097	8.00	25%	18 months
Lehigh St	3V0 Installation	\$865,537	4.50	0%	
Lehigh St	Distribution Line Upgrade	\$1,895,316	9.80	0%	

NYSEG QUALIFYING UPGRADE DISCLOSURE					
Substation	Upgrade	Planning Grade Estimate	Incremental Hosting Capacity (MW)	Percentage Received	Milestone Schedule*
Afton	Substation Transformer	\$4,214,044*	17.25	25%	
Afton	Substation Transformer	\$13,635,548	6.30	0%	
Lehigh St	Line Regulator	\$4,548,497	5.60	0%	
Lehigh St	Substation Transformer	\$9,342,597	6.30	0%	
Locust Street	3V0 Installation	\$865,537	7.30	0%	
Lounsberry	3V0 Installation	\$658,079	19.35	0%	
Limestone	3V0 Installation	\$865,537	4.00	0%	
Limestone	Substation Regulator	\$1,620,638	3.70	0%	
Lounsberry	Distribution Line Upgrade	\$2,608,604	9.80	0%	
Lounsberry	Substation Transformer	\$4,995,680*	19.35	0%	
Lyon Mountain	Distribution Line Upgrade	\$1,092,960	23.00	25%	
Lyon Mountain	Substation Transformer	\$13,822,232	6.30	0%	
Lyon Mountain	Distribution Line Upgrade	\$416,070	23.10	0%	
Lyon Mountain	Substation Transformer	\$11,604,144	17.50	0%	
Macedon	Distribution Line Upgrade	\$621,000	6.01	100%	18 months
Madison Ave	3V0 Installation	\$865,837	8.10	0%	
Madison Ave	Distribution Line Upgrade	\$5,468,488	9.80	0%	
Madison Ave	Substation Regulator	\$1,620,638	5.10	0%	
Masons Corners	3V0 Installation ¹	\$675,945	10.50	65%	18 months
Meyer	Distribution Line Upgrade	\$360,180	1.80	25%	
Montour Falls	Distribution Line Upgrade	\$7,650,720	27.11	0%	
Morrisville	Substation Transformer	\$2,590,894*	8.90	0%	
Morrisville	3V0 Installation	\$865,537	8.70	0%	
Morrisville	Distribution Line Upgrade	\$839,592	7.10	0%	
Moravia	3V0 Installation	\$384,856	4.20	86%	18 months
Montour Falls	Substation Transformer	\$6,946,715*	10.50	0%	
Mountaintdale	3V0 Installation	\$797,610	5.50	0%	
Naples	Distribution Line Upgrade	\$794,880	22.35	100%	18 months
Naples	Substation Regulator	\$535,902	15.14	26%	3-5 years
Naples	Substation Regulator	\$1,568,567	15.14	0%	
New Berlin	3V0 Installation	\$865,537	4.10	0%	
New Berlin	Distribution Line Upgrade	\$541,762	5.60	0%	
New Berlin	Line Regulator	\$1,620,638	2.10	0%	
New Corning	3V0 Installation	\$705,239	16.70	0%	
New Corning	Distribution Line Upgrade	\$530,744	7.60	0%	
North Broadway	3V0 Installation	\$767,024	15.70	21%	
Northside	Distribution Line Upgrade	\$403,650	27.10	100%	18 months
Oaks Corners	3V0 Installation	\$658,243	3.65	96%	18 months
Ouaquaga West	Line Regulator	\$296,935	4.70	0%	
Palmiter Rd	3V0 Installation ²	\$676,057	11.20	18%	
Palmiter Rd	Distribution Line Upgrade	\$1,354,190	9.80	25%	
Palmiter Rd	Substation Transformer	\$4,995,680*	11.20	0%	
Perry Center	Distribution Line Upgrade	\$6,693,138	9.80	0%	
Perry Center	Substation Transformer	\$14,602,194	10.50	0%	
Peruville Tap	Distribution Line Upgrade	\$621,000	25.12	100%	18 months
Philo Road	3V0 Installation	\$549,933	16.80	28%	18 months
Pierce Ave	Distribution Line Upgrade	\$353,098	9.24	89%	18 months
Prattsburg	3V0 Installation	\$737,509	3.50	0%	
Prattsburg	Line Regulator	\$428,509	2.10	0%	
Presho	3V0 Installation	\$660,480	4.09	0%	
Presho	Distribution Line Upgrade	\$3,420,468	3.10	0%	
Richfield Springs	Substation Regulator	\$1,382,624	2.10	0%	
Ridge Rd	Substation Transformer	\$11,313,570	21.70	21%	
Rock Hill	Distribution Line Upgrade	\$315,195	9.80	25%	
Salem Tap	Distribution Line Upgrade	\$1,713,960	8.30	0%	
Seneca Falls	3V0 Installation	\$372,479	6.38	30%	18 months
Seneca Falls	3V0 Installation	\$627,702	6.38	0%	
Seneca Falls	Distribution Line Upgrade	\$1,242,000	7.58	30%	18 months
Seneca Falls	Distribution Line Upgrade	\$707,940	7.58	0%	
Seneca Ordanance	3V0 Installation	\$585,938	5.60	96%	18 months
Silver Creek	Distribution Line Upgrade	\$738,990	TBD	100%	18 months
Silver Springs	Substation Regulator	\$1,620,637	2.10	0%	
Sleight Rd	3V0 Installation	\$676,056	37.45	6%	
Sleight Rd	Distribution Line Upgrade	\$1,366,200	26.50	0%	
South Cooperstown	3V0 Installation	\$708,755	11.40	0%	
South Junction	3V0 Installation	\$444,109	10.50	75%	18 months
South Lansing Tap	Distribution Line Upgrade	\$353,340	27.10	100%	18 months
South Owego	Substation Regulator	\$1,299,312	4.00	0%	
South Owego	Distribution Line Upgrade	\$696,314	8.70	0%	
South Park	3V0 Installation	\$584,322	16.45	23%	
Springfield Center	3V0 Installation	\$665,429	6.30	0%	
St Johns	Distribution Line Upgrade	\$372,600	2.90	0%	
Stanton Ave	3V0 Installation	\$701,175	7.00	43%	18 months
Stanton Ave	3V0 Installation	\$884,582	3.70	0%	
Stolle Rd	Distribution Line Upgrade	\$1,068,644	9.80	0%	
Stolle Rd	Substation Transformer	\$8,808,687*	10.50	0%	
Ten Mile River	3V0 Installation	\$403,896	16.80	30%	18 months
Tilly Foster	3V0 Installation	\$438,558	27.98	25%	18 months
Tom Miller Rd	3V0 Installation	\$865,538	14.70	0%	
Van Buren St	3V0 Installation	\$391,470	10.50	85%	18 months
Van Buren St	3V0 Installation	\$865,537	16.40	0%	
Van Buren St	Distribution Line Upgrade	\$1,490,400	5.50	0%	
Vestal	3V0 Installation	\$700,521	7.60	0%	
Walden	Substation Transformer w/3V0	\$16,371,428	11.20	0%	
Walden	3V0 Installation	\$865,537	5.70	0%	

NYSEG QUALIFYING UPGRADE DISCLOSURE					
Substation	Upgrade	Planning Grade Estimate	Incremental Hosting Capacity (MW)	Percentage Received	Milestone Schedule*
Afton	Substation Transformer	\$4,214,044 ¹	17.25	25%	
Afton	Substation Transformer	\$13,635,548	6.30	0%	
Walden	Distribution Line Upgrade	\$777,182	36.60	0%	
Wallace	3V0 Installation	\$471,577	6.75	0%	
Wallace	Distribution Line Upgrade	\$248,400	9.80	0%	18 months
Wallace	Substation Transformer	\$3,469,599 ¹	6.75	0%	
Warsaw	3V0 Installation	\$327,038	4.99	42%	
Warsaw	Distribution Line Upgrade	\$1,234,989	9.80	0%	
Warsaw	Substation Transformer	\$10,186,981	6.30	0%	18 months
Webbs Crossing	3V0 Installation	\$865,537	5.20	0%	
Wehrle	3V0 Installation	\$865,537	5.40	86%	
Wehrle	Distribution Line Upgrade	\$385,020	3.80	0%	
Wende Rd	Distribution Line Upgrade	\$3,331,315	9.80	0%	18 months
Wende Rd	Substation Transformer	\$5,239,391 ¹	17.50	0%	
West Chazy	3V0 Installation	\$760,897	3.00	0%	
West Chazy	Substation Regulator	\$1,440,955	1.40	0%	
West Geneva	3V0 Installation	\$865,537	3.60	0%	18 months
West Hill	3V0 Installation	\$628,854	6.90	72%	
West Varysburg	Substation Transformer	\$8,078,402 ¹	6.30	0%	
West Winfield	3V0 Installation	\$717,201	5.67	0%	
West Winfield	Substation Transformer	\$3,434,495 ¹	5.67	0%	18 months
Wehrle	3V0 Installation	\$865,537	4.70	0%	
Wehrle	Distribution Line Upgrade	\$385,020	3.80	0%	
Whiskey Creek	3V0 Installation	\$722,814	7.30	0%	
Whiskey Creek	Distribution Line Upgrade	\$2,104,095	6.60	0%	18 months
Whiskey Creek	Substation Transformer	\$13,809,459	13.60	0%	
Windsor	3V0 Installation	\$737,509	4.13	0%	
Windsor	Substation Transformer	\$13,325,070	8.40	0%	
Windsor	Distribution Line Upgrade	\$1,455,725	6.50	0%	18 months
Wright Ave	3V0 Installation	\$402,710	4.90	34%	
Yawger Road	Distribution Line Upgrade	\$324,162	2.00	0%	
Yulan	3V0	\$865,537	5.3	0	

*Material lead time may impact this timeline

**Current Qualifying Upgrade Disclosure queue as of May 19, 2025

¹ Masons Corners 3V0 - 25% pymt made on \$422,192 upgrade

² Palmiter Rd 3V0 - 30% pymt made on \$409,542 upgrade

³ Earlville 3V0 - 48% pymt made on \$518,882 upgrade

⁴ Banker Rd 3V0 - 48% pymt made on \$631,353 upgrade