

RGE QUALIFYING UPGRADE DISCLOSURE					
Substation	Upgrade	Planning Grade Estimate	Incremental Hosting Capacity (MW)	Percentage Received	Milestone Schedule*
S124	3V0 Installation	\$419,702	16.8	0%	
S127	Distribution Line Upgrade	\$1,353,780	9.8	0%	
S142	3V0 Installation	\$773,940	10.5	38%	18 months
S142	Distribution Line Upgrade	\$664,470	8.19	0%	
S145	3V0 Installation	\$656,442	5.135	0%	
S145	Distribution Line Upgrade	\$1,335,150	9.8	0%	
S195	3V0 Installation	\$703,927	5.81	0%	
S195	Substation Transformer	\$4,522,137	10.5	0%	
S198	3V0 Installation	\$639,519	7.38	0%	
S198	Distribution Line Upgrade	\$2,818,800	TBD	0%	
S208	3V0 Installation	\$418,648	5	0%	
S217	3V0 Installation	\$483,729	5.25	38%	18 months
S218	3V0 Installation	\$573,237	12.013	46%	18 months
S218	Distribution Line Upgrade	\$460,534	5.64	0%	18 months
S428	3V0 Installation	\$628,854	4.623	0%	
S428	Distribution Line Upgrade	\$2,142,450	6.05	0%	
S8373	Distribution Line Upgrade	\$509,220	10.464	0%	

\*Material lead time may impact this timeline